



Technical Guidance

Discharge pipes from UVHWSS in garages

Question

Can discharge pipes from unvented hot water storage systems terminate inside garages?

Considerations

- The discharge may not be noticed by the home owner who may be unaware of the problem with the system.

Answer

Discharge pipes from unvented hot water storage systems should not terminate inside garages.