



Technical Guidance

| Dpc trays to rendered walls |

Question

On fully rendered masonry walls do cavity trays need to be provided over openings and roof abutments?
If so do they require weepholes and stop ends?

Considerations

- Wind-driven rain may penetrate rendered masonry through minor cracks and around openings, architectural details, etc.

Answer

Openings

Cavity trays with stop ends are required over all openings. Weepholes do not need to be provided where masonry walls are fully rendered.

Roof abutments

Cavity trays are required at all roof abutments. Weepholes do not generally need to be provided where masonry walls are fully rendered except at the bottom of a stepped cavity tray, where a single weephole should be provided.