



# Technical Guidance

| Dpc trays to rendered walls |

## Question

On fully rendered masonry walls do cavity trays need to be provided over openings and roof abutments?  
If so do they require weepholes and stop ends?

## Considerations

- Wind-driven rain may penetrate rendered masonry through minor cracks and around openings, architectural details, etc.

## Answer

### Openings

Cavity trays with stop ends are required over all openings. Weepholes do not need to be provided where masonry walls are fully rendered.

### Roof abutments

Cavity trays are required at all roof abutments. Weepholes do not generally need to be provided where masonry walls are fully rendered except at the bottom of a stepped cavity tray, where a single weephole should be provided.