



Technical Guidance

| Door limitation devices |

Question

Is a door opening limitation device required where the door has a glazed panel which enables the occupant to identify the caller?

Considerations

NHBC Standards clause 6.7 - D4 provides for a caller to be both seen and spoken to before the door is fully opened.

Answer

A door opening limitation device is required in this situation.