



Technical Guidance

Door between an integral garage and the dwelling - security

Question

Should the door between an integral garage and the dwelling be treated as an internal door or an external door from a security point of view?

Considerations

- NHBC Standards clause 6.7 – D4(d) refers to the security requirement for secondary external access doors to dwellings.
- The security offered by the garage door is unlikely to offer the degree of security described in clause 6.7 – D4(d).

Answer

The door between an integral garage and the dwelling should be treated as a secondary external access door. It should be provided with:

- a 5-lever or cylinder lock fixed securely
- bolts fixed securely at both top and bottom of the door on the internal opening edge.

Where multipoint locking systems are used bolts may be omitted.

Connections between door and/or frame components which can be easily released from outside such as accessible screws should not be used.