

Bedding lintels

(February 2024) (Third issue – supersedes April 2011)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

Question


Can lintels and beams be dry bedded or is it necessary to bed them on mortar?

Considerations

- NHBC Standards clause 6.1.12 states that lintels should be installed level on a solid bed of mortar.
- BS EN 845-2 'Specification for ancillary components for masonry – lintels' states that lintels should be bedded on mortar and levelled.
- Mortar bedding takes out any unevenness between lintels/beams and their support.
- Full contact is required between lintels/beams and their support to reduce the effects of uneven loading, which could cause over stressing of the lintel or the supports.
- Lintels can twist where uniform support is not provided.

Answer

Lintels and steel beams should be bedded on mortar to both leaves to ensure an even distribution of the loads. The thickness of the bedding should be sufficient to accommodate any unevenness between the support and a lintel. Coursing considerations will mean that a full thickness of mortar bedding under the lintel may not always be possible.



Fully bed lintel on both leaves of cavity wall.
Bedding to be kept thin to suit masonry coursing.



NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP
Tel: 0344 633 1000 Web: nhbc.co.uk

National House-Building Council (NHBC) is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority for carrying on insurance business and insurance distribution activities.

NHBC is registered in England and Wales under company number 00320784. NHBC's registered address is NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Buckinghamshire, MK5 8FP. Note that only certain parts of our products and services are within the scope of UK financial services regulations. For more information on our products and services, please see our website nhbc.co.uk or your NHBC product documentation.