

DPC cavity trays in cavity wall construction

(Withdrawn – January 2023)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

Question

On low to medium rise housing developments, what type of flexible damp-proof courses (DPCs) are acceptable for use as a cavity tray?

Considerations

NHBC Standards clause 6.1.17 states 'Cavity trays should be provided at interruptions to the cavity (e.g., window and door openings and air bricks) unless otherwise protected'. It goes on to state, 'Cavity trays should not be low density polyethylene and are to be used in accordance with the manufacturer's recommendation'.

Polyethylene Damp Proof Course made to BS 6515: 1984 are categorised as low-density polyethylene. They are not suitable for use as cavity trays but are suitable for use as a DPC to prevent moisture rising from the ground. For guidance on the design and installation of damp-proof courses in masonry construction, the Code of Practice – BS 8215: 1991 should be referred to.

The purpose of a cavity tray is to prevent the downward movement of water within a cavity and ensure that any water is deflected from the cavity to the exterior of the building envelope.

Answer

Flexible (plastic or rubber) DPC used as a cavity tray should be designed to prevent the downward passage of water or moisture through the tray and meet the requirements of BS EN 14909 and have a third-party certification that confirms their suitability for use as a cavity tray.

Manufacturer's literature confirming their suitability for use as cavity trays should be readily available and their recommendations for appropriate use and installation should be followed.

Low-density polyethylene DPC conforming to BS 6515 alone, are not suitable as cavity trays.

Transition Arrangements

It has come to NHBC's attention that whilst we have provided this guidance within our Standards clause 6.1.17 for some time, several sites have not been following this correctly.

To address this situation, we hereby give notice that on **all plots starting or at DPC level as at 1st January 2023**, the use of appropriate flexible DPCs (as described above) will be required and use of low-density polyethylene DPC conforming only to BS 6515 will no longer be accepted.



NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP
Tel: 0344 633 1000 Web: nhbc.co.uk

National House-Building Council (NHBC) is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority for carrying on insurance business and insurance distribution activities.

NHBC is registered in England and Wales under company number 00320784. NHBC's registered address is NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Buckinghamshire, MK5 8FP. Note that only certain parts of our products and services are within the scope of UK financial services regulations. For more information on our products and services, please see our website nhbc.co.uk or your NHBC product documentation.