

# Wall plates – bedding, lengths and joints

(May 2024) (Second issue – supersedes December 2008)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

## Question

1. Do wall plates need to be bedded on mortar in every situation?
2. Are wall plates which are less than 3m in length acceptable?
3. Are butt joints in wall plates acceptable and do they need strapping?

## Considerations

- Bedding the wall plate helps to distribute the roof load onto the masonry: if the wall plate is not bedded, the wall plate or blockwork may be crushed locally.
- NHBC Standards clause 7.2.6 says:
  - Wall plates should be in lengths not less than 3m long and joined using half-lapped joints at corners and in running lengths.
  - In Scotland, 100mm x 25mm wall plates should be used, in long lengths, butt jointed.
- BS 8000: part 5 'Workmanship on building sites' says wall plate lengths less than 3m should be in one piece and of sufficient length to support at least three joists or trusses where required.

## Answer

1. Wall plates should be bedded on mortar. If inspection reveals this has not been done, the blockwork should be inspected for signs of damage and made good as required. Dry mortar should be carefully packed under the full width of the wall plate.
2. Whenever practicable wall plates should be in lengths not less than 3m. Where this is not practicable (e.g. if the length of the wall is 5m) wall plates may be shorter lengths. Each length should support at least three joists or trusses.
3. In England, Wales and Northern Ireland wall plates should be jointed with half-lapped joints. Butt joints should not be used but if found should be jointed with metal or timber strapping across the joint. Where used (in Scotland only) 25mm deep wall plates may be butt jointed and fixed to the top of the wall with a nail either side of the butt joint. Strapping across the joint is not essential but would assist load transfer. Wall plates deeper than 25mm should be jointed with half-lapped joints.



**NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP**  
**Tel: 0344 633 1000 Web: nhbc.co.uk**

National House-Building Council (NHBC) is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority for carrying on insurance business and insurance distribution activities.

NHBC is registered in England and Wales under company number 00320784. NHBC's registered address is NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Buckinghamshire, MK5 8FP. Note that only certain parts of our products and services are within the scope of UK financial services regulations. For more information on our products and services, please see our website [nhbc.co.uk](http://nhbc.co.uk) or your NHBC product documentation.