

# Canopy flashings

(May 2024) (Second issue – supersedes December 2024)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

## Question

Should flashings be provided to canopy roofs?

## Considerations

- NHBC Standards clause 7.2.20 says, 'where a roof abuts a vertical surface, cover flashings, stepped flashings, soakers and back or parapet gutters should be provided as necessary'.
- NHBC Standards clause 7.2.20 says, 'where a roof is over an enclosed area, the wall construction should include cavity trays linked to the flashings'.
- Seepage of rainwater between the canopy and wall may cause damage to the canopy structure.

## Answer

Canopy roofs constructed on site should be provided with flashings at the abutment with the wall, regardless of whether there is an enclosed or an open space below. Where there is an enclosed space below, the flashing should be linked to a cavity tray.

Prefabricated (GRP) canopies located over an open space can be installed without flashings but should be sealed back to the wall with a suitable sealant such as silicone, to minimise rainwater ingress. Prefabricated canopies located over an enclosed space should be provided with flashings linked to cavity trays.



**NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP**  
**Tel: 0344 633 1000 Web: nhbc.co.uk**

National House-Building Council (NHBC) is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority for carrying on insurance business and insurance distribution activities.

NHBC is registered in England and Wales under company number 00320784. NHBC's registered address is NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Buckinghamshire, MK5 8FP. Note that only certain parts of our products and services are within the scope of UK financial services regulations. For more information on our products and services, please see our website nhbc.co.uk or your NHBC product documentation.