

## Acceptance certificate

**Issue date:** 01/02/2022  
**Reference number:** 3895  
**Issue:** 01  
**Innovative Product Owner:** Saint-Gobain Construction Product UK Ltd t/a Saint-Gobain Weber  
Saint-Gobain House, East Leake, Loughborough, LE12 6JU  
**Innovative Product name:** 'weberend MT Systems'  
**Generic form:** Render System

NHBC Services Ltd has reviewed the following information (the System Manual) related to the Innovative Product supplied by the Innovative Product Owner:

- BBA Agrément certificate 20/5790 Product sheets 1 and 2

Relying on the information provided by the Innovative Product Owner, NHBC Services Ltd considers that the Innovative Product can meet NHBC Standards.

Additional requirements must be met in order for a new home to qualify for Buildmark cover. Buildmark cover for new homes will only be issued to Builders or Developers in accordance with the latest version of the NHBC Rules (a copy of which can be found at [www.nhbc.co.uk](http://www.nhbc.co.uk)).

This acceptance certificate is valid until such time as it is no longer published or authorised by NHBC. Readers are advised to check the validity and latest issue number of this Certificate by either referring to our website at [www.nhbc.co.uk/accepts](http://www.nhbc.co.uk/accepts) or contacting NHBC directly.

**Issued by:**



Innovation Services Manager  
NHBC Services Ltd

## Acceptance certificate

### **Description, Scope and intended use**

'weberend MT Systems' is a factory produced set of products for use as ventilated and drained exterior wall cladding systems on timber and steel-frame buildings. There are options for two panel types with the Systems applied to Siniat Bluclad Board or Knauf Aquapanel Exterior Cement Board, and for either a silicone or acrylic based thin coat render finish, or a brick slip finish. The set of products will be referred to as the System.

The System must be assessed on a project basis. A design engineer must consider the design and installation of the System, and the associated support system in accordance with NHBC Technical Requirement R5.

Design of System finishes must be in accordance with BS EN 13914-1:2016 'Design, preparation and application of external rendering and internal plastering'.

---

### **Extent of review for NHBC Warranty on NHBC Registered Sites**

NHBC Services Ltd has undertaken a technical review of the System Manual as set out in line with the NHBC Accepts Technical Document for Innovative Products.

The NHBC Accepts Service is intended solely to provide confidence that the Innovative Product meets NHBC Standards and is not intended as evidence of performance for any other purpose. Appraisal of the Innovative Products against building regulations is not carried out as part of this Service.

---

### **Exclusions and Limitations**

This Acceptance Certificate is made out solely to the System Owner. To the fullest extent permitted by law, we do not accept or assume responsibility to anyone other than the System Owner arising out of, or in connection with, this Acceptance Certificate.

Exclusions and limitations are set out in the System Manual. Additional considerations in the use of the Innovative Product include:

- A full installation specification should be obtained for each site from the Product Owner, to take account of:
  - preliminary treatment of the background
  - position of beads
  - detailing around windows, doors and at eaves
  - areas where flexible sealants must be used.