# TECHNICAL GUIDANCE 4.2/01

# Strip/trench fill foundations - slip membranes

(December 2008) (First issue)



## Question

Is a slip membrane needed to the outer face of the excavation for a strip/trench fill foundation in shrinkable soil?

### **Considerations**

- The vertical face of the excavation needs to be sufficiently smooth to allow movement of the soil to take place without disturbing the foundation.
- A slip membrane would do little to reduce the friction between the clay and the foundation.

#### **Answer**

A slip membrane is not needed. The vertical face of the excavation should be reasonably smooth.

