

Movement joints in masonry – timber framed external walls

(December 2008) (First issue)



Question

Are slip ties required across movement joints in masonry cladding to timber frame walls?

Considerations

- NHBC Standards clause 6.1.18 says at movement joints, wall ties should be spaced at maximum 300mm centres vertically within 225mm of the joints on both sides of the joint. The ties provide lateral restraint to the unrestrained ends of the masonry wall.
- Wall ties should be fixed over a timber stud. The spacing of the studs is often more than 225mm from the movement joint. The addition of extra studs, within 225mm of the movement joint, may be impractical.
- Slip ties, inserted across the movement joint, can be used to tie the end of the wall in place of additional wall ties within 225mm of the movement joint.

Answer

The need for and provision of slip ties across movement joints should be decided in accordance with the following diagram:

