

# Air admittance valves

(Withdrawn – January 2024)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

## Question

Where an air admittance valve (AAV) is enclosed within a boxing should the boxing be ventilated?

## Considerations

- An AAV requires a free movement of air around the valve to ensure its effective operation.
- Third party assessments state any boxing around an AAV should be ventilated although guidance is not given on the amount and method of ventilation.
- Approved Document H (England and Wales) states, 'Air admittance valves should be located in areas which have adequate ventilation'.

## Answer

Where an AAV is enclosed in a boxing the boxing should be ventilated. The use of ventilation grilles, discreet gaps around the boxing or ventilation of the boxing into a ventilated roof void are some acceptable methods of providing ventilation. In the absence of manufacturer's instructions, a free area of 2500mm<sup>2</sup> is considered reasonable provision.



**NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP**  
**Tel: 0344 633 1000 Web: nhbc.co.uk**

National House-Building Council (NHBC) is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority for carrying on insurance business and insurance distribution activities.

NHBC is registered in England and Wales under company number 00320784. NHBC's registered address is NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Buckinghamshire, MK5 8FP. Note that only certain parts of our products and services are within the scope of UK financial services regulations. For more information on our products and services, please see our website [nhbc.co.uk](http://nhbc.co.uk) or your NHBC product documentation.