

Pipe insulation with combi boilers

(Withdrawn – January 2024)

The Technical Guidance Notes are produced by NHBC as guidance solely for our builder customers as to how to interpret the technical requirements in relation to the warranty cover provided by NHBC under its Buildmark, Buildmark Choice, Buildmark Link, Buildmark Solo, Buildmark Connect or any similar product from time to time. It has not been created or intended for distribution or use outside of that purpose. The information contained in this Technical Guidance Note does not constitute advice and is not to be relied upon by any third party. Nothing in this Technical Guidance Note is intended to, nor should it be taken to, create any legal or contractual relationship. Any third party who chooses to rely upon the information contained in the Technical Guidance Notes shall do so entirely at their own risk and NHBC accepts no duty of care or liability, however caused, in connection with its use or reliance by any third party.

Question

Is there a need to insulate the central heating pipework between a combi boiler and a remote by-pass valve?

Considerations

- Approved Document L1A clause 2.42 'Heat losses and gains from circulation pipes' says, 'reasonable provision should be made to limit heat losses from pipes as set out in the 'Domestic Building Services Compliance Guide'.
- Table 5 of the Domestic Building Services Compliance Guide refers to a TIMSA guide on compliance with Part L of the Building Regulations.
- The TIMSA guide illustrates where insulation should be applied to primary and secondary heating and hot water circuits. One diagram suggests the need for insulation to the central heating pipework between a combi boiler and a remote by-pass valve.

Answer

A by-pass valve, fitted between the flow and return pipework on the central heating circuit, maintains a flow rate through the boiler to dissipate surplus heat in the heat exchanger when the zone valves or thermostatic radiator valves turn off.

When a demand for hot water stops, depending on the design of the combi boiler, the surplus heat in the heat exchanger is pumped and dissipated either through pipework within the boiler or through the by-pass valve outside the boiler.

Both with heating and hot water demands once the surplus heat has dissipated the circulation pump switches off and the flow stops.

Provided the surplus heat from the pipework between the boiler and the by-pass valve is dissipated within the heated area of the dwelling the pipework can be left uninsulated.



NHBC, NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks MK5 8FP
Tel: 0344 633 1000 Web: nhbc.co.uk

National House-Building Council (NHBC) is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority for carrying on insurance business and insurance distribution activities.

NHBC is registered in England and Wales under company number 00320784. NHBC's registered address is NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Buckinghamshire, MK5 8FP. Note that only certain parts of our products and services are within the scope of UK financial services regulations. For more information on our products and services, please see our website nhbc.co.uk or your NHBC product documentation.