

Earth bonding plastic plumbing

(December 2008) (First issue)



Question

Does the cold water service need to be earth bonded if the majority of the plumbing and heating pipework in the house is plastic?

Considerations

- See Standards Extra Issue 18, August 1999 for further information.

Answer

Where all plumbing and heating pipework except radiator tails, etc. is plastic, there is no requirement for earth bonding the cold water service.